



Number	KIP-16434/G	Replaces	KIP-16253/G
Issue date	22-10-2019	Contract number	I 0220
Due date	21-10-2029	Scope	(EU) 2016/426 (9 March 2016)
Report number	2001134/6	Module	B (Type testing)
PIN	0476CS1134		

EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the central heating condensing boiler, type(s):

**PERFECTA 25 SK, PERFECTA 25 RK, PERFECTA PLUS 25 SK,
PERFECTA 30 SK, PERFECTA 30 RK, PERFECTA PLUS 30 SK,
PERFECTA 35 SK, PERFECTA 35 RK, PERFECTA PLUS 35 SK,
PERFECTA INN 25 SK, PERFECTA INN 35 SK,
PERFECTA EXT 25 SK, PERFECTA EXT 35 SK,
PERFECTA PREMIUM 25 SK, PERFECTA PREMIUM 35 SK**

Manufacturer

BALTUR s.p.a.
Via Ferrarese,
44042, Cento (FE), Italy

Meet the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-1:2012+A1:2015, EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)
Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

GASTEC

Chief Operating Officer
Giampiero Belcredi



Number KIP-16434/G **Page** 1 of 1
Issue date 22-10-2019 **Scope** (EU) 2016/426 (9 March 2016)
Due date 21-10-2029 **Module** B (Type testing)
Report number 2001134/6
PIN 0476CS1134

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Brand name:
BALTUR

Types:

Model name	Heat Input (Hi)	
	CH Max – Min (kW)	DHW Max – Min (kW)
PERFECTA 25 SK, PERFECTA 25 RK, PERFECTA PLUS 25 SK, PERFECTA INN 25 SK, PERFECTA EXT 25 SK,	20,0 – 2,5	25,0 – 2,5
PERFECTA 30 SK, PERFECTA 30 RK, PERFECTA PLUS 30 SK	24,0 – 3,0	30,0 – 3,0
PERFECTA 35 SK, PERFECTA 35 RK, PERFECTA PLUS 35 SK, PERFECTA INN 35 SK, PERFECTA EXT 35 SK	28,0 – 3,5	33,2 – 3,5

Model name	Heat Input (Hi)			
	CH Max – Min (kW)		DHW Max – Min (kW)	
	All gas fam. except M and P	Gas fam. M and P	All gas fam. except M and P	Gas fam. M and P
PERFECTA PREMIUM 25 SK	25,0 – 1,6	24,3 – 2,5	25,0 – 1,6	24,3 – 2,5
PERFECTA PREMIUM 35 SK	33,0 – 1,6	32,5 – 2,5	34,9 – 1,6	34,5 – 2,5

Appliance types:

B₂₃, B₅₃, B_{23P}, B_{53P}, C₁₃, C₃₃, C₄₃, C₅₃, C₆₃, C₈₃, C₉₃

Countries:

AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Gas groups:

Group	mbar
E	20
H	20;25
Esi	20/25

Group	mbar
E(R)	20
E(S)	20
Er	20/25

Group	mbar
M	20
P	30; 37; 50

The above gas groups can be combined according to the standard EN437:2018 and national situation of countries.

Remarks:

None

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.